


OFFICE USE ONLY
Log No. 65001
Permit No. _____
Basin 14a



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34696
Silverpick Mine
Goldfield, NV

1. OWNER American Pacific Minerals ADDRESS AT WELL LOCATION _____
MAILING ADDRESS Goldfield, NV _____
2. LOCATION NW 1/4 NW 1/4 Sec 35 T 2 N R 42 E Esmeralda, CO. County
PERMIT NO. MD 2772 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>MW #5</u>				
<u>SAND - SMALL BOULDERS</u>		<u>0'</u>	<u>7'</u>	<u>7'</u>
<u>WEATHERED VOLCANIC ROCK</u>		<u>7'</u>	<u>34'</u>	<u>27'</u>
<u>SAND /w trace OF gravel + clay</u>		<u>34'</u>	<u>45'</u>	<u>11'</u>
<u>Volcanic Rock</u>		<u>45'</u>	<u>59'</u>	<u>14'</u>

97 FT 2 1/2" PIPING
STARTED AT 10:00 AM

8. WELL CONSTRUCTION
Depth Drilled 59' Feet Depth Cased 59' Feet
HOLE DIAMETER (BIT SIZE)
From 8" To 0" Feet 59' Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.37</u>		<u>SCH 40</u>	<u>0</u>	<u>29</u>

Perforations:
Type perforation BRASS SCREEN
Size perforation 0.020
From 29 feet to 59 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 10' cement 9' bent. Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 19' feet to 59' feet

9. WATER LEVEL
Static water level 33.9' feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name NEVADA DRILLING INC. Contractor
Address 75 Lewers creek RD Contractor
CARSON CITY NV 89704
Nevada contractor's license number 13697A issued by the State Contractor's Board.
Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 1902
Signed John G. Sewer
By driller performing actual drilling on site or contractor
Date 4.23.97



Date started 3.24 1997
Date completed _____ 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)