WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65040
Permit No.
Basin 212

NOTICE OF INTENT NO. 15923

1. OWNER Southern Nevada Water Authority
MAILING ADDRESS 1850 E. Flamingo Road
Las Vegas, NV 89119

ADDRESS AT WELL LOCATION ≈75 feet south of Charleston Blvd and ≈ 500 feet east of the Sloan Channel.

2. LOCATION NW ¼ NW ¼ Sec. 3 T. 21 N/S R. 62 E. Clark County
PERMIT NO. Issued by Water Resources | 161-03-196-001 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE O-22A
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG O-22A

Material	Water Strata	From	To	Thickness
Fill: sandy silt		0'	3'	3'
Clayey silt		3'	8'	5'
Silty clay		8'	11'	3'
Silty sand		11'	13'	2'
Sandy clay		13'	15'	2'
Clayey Sand		15'	22'	7'
Sandy Clay		22'	40'	18'

MAY 13 1997

Date started March 26, 1997
Date completed March 26, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 39 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
8	0	40

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	39

Perforations:
Type perforation Factory Slot
Size perforation 0.020"
From 19 feet to 39 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0'-1' neat cement, 15'-17' bentonite
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 17 feet to 39 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thomas High (Contractor)
Address 731 Pilot Road, Suite H (Contractor)
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869
Signed (By driller performing actual drilling on site or contractor)
Date 4-23-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627