



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15625

1. OWNER City of Las Vegas - Office of Business Development ADDRESS AT WELL LOCATION Southeast corner of 400 Las Vegas Blvd. South Las Vegas, NV 89101  
Las Vegas, NV 89101 ADDRESS AT WELL LOCATION Las Vegas Blvd. South and Clark Avenue

2. LOCATION NE 1/4 SW 1/4 Sec 34 T. 20 N. R. 61 E Clark County  
 PERMIT NO. MO-2762A Issued by Water Resources | 139-34-310-061, 062, 063, 074 and 139-34-710-01 Parcel No. | Clark Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE MW-3  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG MW-3

Material	Water Strata	From	To	Thickness
Clayey Silt		0'	1.5'	1.5'
Sandy Clayey Silt		1.5'	2.5'	1.0'
Silty Clay		2.5'	4.5'	2.0'
Gravelly Clayey Silt		4.5'	7.0'	2.5'
Caliche		7.0'	14.0'	7.0'

8. WELL CONSTRUCTION  
 Depth Drilled 14 Feet Depth Cased 14 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9 Inches To 9 Feet  
 From 0 Inches To 14 Feet  
 From 0 Inches To 14 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.64</u>	<u>0.154"</u>	<u>0</u>	<u>14</u>

Perforations:  
 Type perforation Factory Slot  
 Size perforation 0.020"  
 From 4 feet to 14 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 9-11' neat cement  Neat Cement  
Bentonite  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 3 feet to 14 feet

9. WATER LEVEL  
 Static water level 7.5 feet below and surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

7. WELL TEST DATA  
 TEST METHOD:  Bailer  Pump  Air Lift  
 Date started February 25 1997  
 Date completed February 25 1997

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Thomas High Contractor  
 Address 731 Pilot Road, Suite H Las Vegas, NV 89119  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 4-23-97