WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65643
Permit No.
Basin 212

NOTICE OF INTENT NO. 15625

1. OWNER City of Las Vegas - Office of Business Development
MAILING ADDRESS 400 Las Vegas Blvd. South, Las Vegas, NV 89101
ADDRESS AT WELL LOCATION Southeast corner of Las Vegas Blvd South and Clark Avenue

2. LOCATION NE ¼ SW ¼ Sec. 34 T. 20 ~~N~~ S R. 61 E. Clark County
PERMIT NO. MO-2762A (Issued by Water Resources)
Parcel No. 139-34-310-061, -062, -063, -074 and 139-34-710-01

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MW-4
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG MW-4

Material	Water Strata	From	To	Thickness
Fill: gravelly silty sand		0'	2'	2'
Clayey Silt		2'	3.5'	1.5'
Silty Clay		3.5'	6.5'	3'
Sandy Silty Clay		6.5'	8'	1.5'
Silty Clay		8'	12.5'	4.5'
Caliche		12.5'	14'	1.5'

Date started February 25, 19 97
Date completed February 25, 19 97

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 14 Feet Depth Cased 14 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 Inches		0 Feet	14 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	14

Perforations:
Type perforation Factory Slot
Size perforation 0.020"
From 4 feet to 14 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0'-1' neat cement, 1'-3' bentonite
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 3 feet to 14 feet

9. WATER LEVEL
Static water level 8 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thomas High (Contractor)
Address 731 Pilot Road, Suite H (Contractor)
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1869
Signed (By driller performing actual drilling on site or contractor)
Date 4-23-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627