


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 65049
 Permit No. 162
 Basin 162



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15528

1. OWNER Strickland Const. Co., Inc. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 2301 Winery Road Ste 2 60 West Gally Pahrump, Nevada 89048
Pahrump, NV 89048

2. LOCATION NE 1/4 NE 1/4 Sec. 28 T 19S N/S R 53E E Nye County
 PERMIT NO. 27-371-15 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Loam		0	3	3
Brown Clay		3	20	17
Light Brown Clay		20	35	15
Brown Calichia		35	59	24
Light Brown Calichia	x	59	76	17
Brown Calichia	x	76	102	26
Light Brown Clay	x	102	126	24
Brown Calichia	x	126	143	17
Dark Brown Clay	x	143	162	19
Brown Clay	x	162	185	23

8. WELL CONSTRUCTION
 Depth Drilled 185 Feet Depth Cased 185 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 3/4 Inches To 0 Feet 185 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	185

Perforations:
 Type perforation TORCH
 Size perforation .25 x 6
 From 132 feet to 153 feet
 From 175 feet to 185 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 185 feet

9. WATER LEVEL
 Static water level 75 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2025 2035
 Signed Harry Strickland
 By driller performing actual drilling on-site or contractor
 Date 5-6-97

Date started 5/6/97, 19____
 Date completed 5/6/97, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>	<u>n/a</u>	<u>.50</u>

