WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65052
Permit No.
Basin 1162

NOTICE OF INTENT NO. 15526

1. OWNER Steve and Joy Krogh
MAILING ADDRESS 3611 Unicorn Ave.
Pahrump, NV 89048

ADDRESS AT WELL LOCATION
3611 Unicorn Ave., Pahrump, Nevada 89048

2. LOCATION NW 1/4 SW 1/4 Sec. 35 T 20S N/S R 53E E Nye County
PERMIT NO. Issued by Water Resources
41-121-04 Parcel No.
Calvada Valley Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sandy Loam		0	2	2
Brown Calichia		2	8	6
Grey Calichia		8	14	6
White Calichia		14	18	4
Brown Calichia		18	24	6
Brown Clay		24	44	20
Brown Calichia		44	58	14
Dark Brown Calichia	x	58	63	5
Light Brown Clay	x	63	79	16
Light Brown Calichia	x	79	94	15
Light Brown Clay	x	94	112	18
Dark Brown Clay	x	112	121	9
Brown Calichia	x	121	140	19

DCNR/DWR Received MAY 7 1997 LAS VEGAS OFFICE

Date started 4/26/97 , 19__
Date completed 4/28/97 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50	na	.50

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 3/4	Inches	0 Feet	140 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	140

Perforations:
Type perforation TORCH
Size perforation .25 x 6
From 138 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Strickland Construction Co., Inc. Contractor
Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2025
Signed Larry Strickland By driller performing actual drilling on-site or contractor
Date 5/5/97