WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65061
Permit No.
Basin 230

NOTICE OF INTENT NO. 16087

1. OWNER HARVEY, JANET
MAILING ADDRESS WHITE SANDS ROAD
AMARGOSA, NV

ADDRESS AT WELL LOCATION WHITE SANDS ROAD

2. LOCATION SW 1/4 NW 1/4 Sec. 35 T 16S N/S R 49E E NYE County
PERMIT NO. _____ Issued by Water Resources | 19-631-49 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND & GRAVEL		0	40	40
CEMENTED GRAVEL		40	44	4
CLAY		44	62	18
CEMENTED GRAVEL		62	69	7
CLAY		69	95	26
GRAVEL	WB	95	120	25
CEMENTED GRAVEL		120	125	5
GRAVEL	WB	125	139	14
CALICHIE	WB	139	148	9
GRAVEL	WB	148	155	7

Date started 4/29/97, 19__
Date completed 5/1/97, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12.25	Inches	0	Feet	155	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8.625	16.94	.188	0	155

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1/8 X 3
From 135 feet to 155 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 155 feet

9. WATER LEVEL

Static water level 90 feet below land surfac
Artesian flow ____ G.P.M. ____ P.S.I
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Co. (Contractor)
Address PO BOX 4220 (Contractor)
PAHRUMP, NV 89041

Nevada contractor's license number issued by the State Contractor's Board 30880

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed Thomas Dunn
By driller performing actual drilling on-site or contractor

Date 5/1/97