WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65064
Permit No.
Basin 162

NOTICE OF INTENT NO. 16084

1. OWNER PAHRUMP CONCRETE
MAILING ADDRESS 3660 S VERDE
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION
3660 S VERDE

2. LOCATION SE 1/4 SW 1/4 Sec. 32 T 20S N/S R 53E E NYE County
PERMIT NO. 40-572-16 (Issued by Water Resources / Parcel No.)
CALVADA VALLEY (Subdivision Name)

**3. WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

**4. PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

**5. WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| CLAY & CALICHIE | | 0 | 85 | 85 |
| CALICHIE | WB | 85 | 97 | 12 |
| CLAY | | 97 | 112 | 15 |
| CALICHIE | WB | 112 | 123 | 11 |
| CLAY | | 123 | 134 | 11 |
| CALICHIE | WB | 134 | 140 | 6 |

Date started 4/7/97, 19__
Date completed 4/11/97, 19__

**7. WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

**8. WELL CONSTRUCTION**
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12.25 Inches | | 0 Feet | 140 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8.625 | 16.94 | .188 | 0 | 140 |

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1/8 X 3
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

**9. WATER LEVEL**
Static water level 54 feet below land surfac
Artesian flow G.P.M. P.S.I
Water temperature °F Quality

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Great Basin Drilling Co. (Contractor)
Address PO BOX 4220 (Contractor)
PAHRUMP, NV 89041

Nevada contractor's license number issued by the State Contractor's Board 30880

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642

Signed Thomas Dun
By driller performing actual drilling on-site or contractor

Date 4/30/97

MAY 12 '97