WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65068
Permit No.
Basin 212

NOTICE OF INTENT NO. 17834

1. OWNER CIRCLE K CORPORATION
MAILING ADDRESS 3003 N. CENTRAL AVENUE
PHOENIX, ARIZONA 85012

ADDRESS AT WELL LOCATION CIRCLE K
450 N. WATER ST
HENDERSON NV

2. LOCATION SE ¼ SW ¼ Sec. 7 T. 22 N/S R. 63 E. CLARK County
PERMIT NO. ____ Issued by Water Resources | 17907410001 Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BR: SANDY,		0		
SILTY GRAVELS				
W/COBBLES			45	45'
CLAY W/ FINE ▼	55	45'		
SAND LENS			65	20'

RECEIVED 97 MAY 7 AM 9:37 STATE ENGINEER'S OFFICE

Received MAY 12 1997 DIVISION OF WATER RESOURCES

Date started APRIL 9, 1997
Date completed APRIL 11, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 65' Feet Depth Cased 65 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
8.75	0	65

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.25		SCH 40	0	45

Perforations:
Type perforation SLOT
Size perforation .020
From 45 feet to 65 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 40'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 42 feet to 65 feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WEST HAZMAT DRILLING Contractor
Address 1016 E. KATELLA, ANAHEIM Contractor
CA, 92805
Nevada contractor's license number issued by the State Contractor's Board 31386
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1200
Signed ____ By driller performing actual drilling on site or contractor
Date APRIL 19, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627