

OFFICE USE ONLY
 Log No. 65094
 Permit No. _____
 Basin. _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21668

Consultant:

1. OWNER EBASCO INFRASTRUCTURE
 MAILING ADDRESS 2525 Natomas Park Dr. Suite 250
Sacramento, Ca. 95833-2900
 ADDRESS AT WELL LOCATION Sierra Pacific Power Co.
Tracy Clark Power Station
I-80 East, Sparks Nevada
 2. LOCATION NE 1/4 NW 1/4 Sec. 33 T. 20N N/S R. 22E E Storey County
 PERMIT NO. M/O 381-A MW 5 04-091-11 E of Cooling Pond, between pond & river
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other TUBEX

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
GRAVEL, pebbles up to 1 inch diam., w/sandy matrix		0	3	3
Grades sandier. Grades to SAND w/minor gravels.		3	5	2
Grades back to mod. dense SANDY GRAVEL.		5	14	9
Dark brown, mod. dense SANDY GRAVEL. Strange organic smell.		14	17	3
Boulders (many frags in cuttings). Cuttings essentially all the same composition. Cuttings are mostly frags, but are not fresh breaks.		17	19	2

8. WELL CONSTRUCTION
 Depth Drilled 19.4 Feet Depth Cased 18.5 Feet
 HOLE DIAMETER (BIT SIZE)
 From 7 1/2 Inches To 0 Feet 19.4 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2" PVC		sch 40	0	18.5

Bottom cap, Locking cap, Flush cover
 Stainless Steel Centralizers 8' & 18'

Perforations:
 Type perforation Factory sawed slot
 Size perforation 0.02
 From 8.5 feet to 18.5 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 4.5
 Placement Method: Pumped Poured
 Cement Grout Concrete Grout
 Bentonite Seal: 4.5 - 6.5
 Gravel Packed: Yes No #3 Lone star sand
 From 6.5 feet to 19.4 feet

9. WATER LEVEL
 Static water level 11.6 feet below land surface
 Artesian flow _____ G.P.M. N/A P.S.I.
 Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC.
Contractor
 Address P.O. BOX 12370
Contractor
RENO, NEVADA 89510
 Nevada contractor's license number issued by the State Contractor's Board. 22549
 Nevada driller's license number issued by the Division of Water Resources the on-site driller. 908
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date June 12, 1996

Date started 3-15-93, 19_____
 Date completed 3-15-93, 19_____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
No test			
Well information recieved via FAX 6-9-96			