

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28123  
12340

1. OWNER Buck Schaechtler ADDRESS AT WELL LOCATION Shawnee Rd  
MAILING ADDRESS 12340 Shawnee Rd Dayton NV 89706  
LOCATION SE 1/4 SE 1/4 Sec 12 T 17 N R 22 E 1400 County  
PERMIT NO. 15-321-02 Issued by Water Resources Parcel No. Iron Mtn. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Coarse Boulders</u>		<u>0</u>	<u>30</u>	<u>30</u>
<u>Coarse Gravels and Sands</u>		<u>30</u>	<u>65</u>	<u>35</u>
<u>Coarse DG Sands</u>		<u>65</u>	<u>120</u>	<u>65</u>
<u>DG Gravels</u>		<u>120</u>	<u>189</u>	<u>79</u>
<u>Fracture Granite</u>		<u>189</u>	<u>280</u>	<u>31</u>
<u>Rusty Stained Granite w/ Volcanic Rock Seams</u>	<u>xxx</u>	<u>280</u>	<u>265</u>	<u>45</u>

8. WELL CONSTRUCTION  
Depth Drilled 265 Feet Depth Cased 265 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10 1/4</u>	<u>0</u>	<u>50</u>	<u>0</u>	<u>50</u>
<u>9 7/8</u>	<u>50</u>	<u>265</u>	<u>50</u>	<u>265</u>

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>265</u>

Perforations:  
Type perforation Mill Slot  
Size perforation 3 x 3/32  
From 245 feet to 265 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
Depth of Seal 55  Cement Grout  
Placement Method:  Pumped  Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 55 feet to 265 feet

9. WATER LEVEL  
Static water level 70 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. 20+ P.S.I.  
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name A. H. Pump Contractor  
Address 5551 Hwy 50 E #3 Contractor  
Carson City NV 89701  
Nevada contractor's license number issued by the State Contractor's Board 31839  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
Signed W. H. L. L. L.  
By driller performing actual drilling on site or contractor  
Date 3-10-96

Date started 3-1 1996  
Date completed 3-5 1996

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>20+</u>	<u>45</u>	<u>3 HRS</u>	