WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65121
Permit No.
Basin 163

NOTICE OF INTENT NO. 29374

1. OWNER Bob Meares
MAILING ADDRESS 11220 Silver Ln Stagecoach NV
ADDRESS AT WELL LOCATION Stage Coach 11220 Silver Ln

2. LOCATION NW ¼ NW ¼ Sec. 19 T. 17 N/S R. 23 E. Lyon County
PERMIT NO. (Issued by Water Resources) 19-391-05 (Parcel No.) Stagecoach (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay Sand | | 0 | 25 | 25 |
| Pea Gravel | | 25 | 50 | 25 |
| Sand Washed Gravel | | 50 | 75 | 25 |
| Clay Sand streaks | | 75 | 100 | 25 |
| Sand Clay layers | | 100 | 125 | 25 |
| Pea Gravel Sand | * | 125 | 150 | 25 |
| Pea Gravel, Sand | * | 15 | 160 | 10 |

Date started 4/2/96, 19
Date completed 4/2/96, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20+ | | 1 |

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased +1 to 160 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 9 7/8 | 0 | 160 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 14 | .188 | +1 | 160 |

Perforations:
Type perforation Factory milled
Size perforation 3/32
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow N/A G.P.M. 20+ P.S.I.
Water temperature Cold °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Enloe Drilling (Contractor)
Address PO Box 1345 Dayton NV 89403 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 4739A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1757
Signed Troy Enloe (By driller performing actual drilling on site or contractor)
Date 4/2/96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627