

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 33233

1. OWNER Erick Ramsey ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1555 Freeport Blvd. #21 2000 Road Runner Rd.  
Sparks NV 89431  
 2. LOCATION NW 1/4 SW 1/4 Sec 26 T.23 N. 20 E. 1/4 35005 County  
 PERMIT NO. 076-210-16 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown D.G.		0	8	8
White, black course sand (soft)		8	20	12
Multi colored course sand		20	70	50
Weathered salt & pepper Granite Soft		70	120	50
Weathered Salt & pepper Granite				
Brown clay		120	145	50
Weathered Salt & pepper granite (soft)	X	145	195	50
T.D.				195'

8. WELL CONSTRUCTION  
 Depth Drilled 195' Feet Depth Cased 195' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 195' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.92</u>	<u>188</u>	<u>+1 1/2</u>	<u>195'</u>

Perforations:  
 Type perforation Factory Sawn  
 Size perforation 3/32 X 3  
 From 1.68' feet to 1.88' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Poured  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 195' feet to 50' feet

9. WATER LEVEL  
 Static water level 140' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality \_\_\_\_\_

Date started November 26, 1996  
 Date completed December 4, 1996

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>2 Hours</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A.S.A.P. Pump & Well Service, Inc.  
 Address 1800 1/2 Frazer Ave.  
Sparks NV 89431  
 Nevada contractor's license number issued by the State Contractor's Board. 95387-A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller. 1509  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date December 16, 1996