WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65157
Permit No.
Basin 101

NOTICE OF INTENT NO. 30804

1. OWNER Bill & Gina Baker
MAILING ADDRESS 4455 Soda Lake Rd.
Fallon, Nv 89406

ADDRESS AT WELL LOCATION
4455 Soda Lake Rd.
Fallon, Nv 89406

2. LOCATION NE ¼ NE ¼ Sec. 17 T. 19 N/S R. 28 E Churchill County

PERMIT NO. (Issued by Water Resources) | Parcel No. 08-071-66 | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Brown Sand | | 0 | 20 | 20 |
| Brown Clay | | 20 | 30 | 10 |
| Brown Sand | | 30 | 37 | 7 |
| Brown Clay | | 37 | 50 | 13 |
| Green Sand | | 50 | 80 | 30 |
| Gray Clay | | 80 | 95 | 15 |
| Gray Sand | | 95 | 110 | 15 |
| Brown Clay | | 110 | 113 | 3 |
| Brown Sand | X | 113 | 138 | 25 |

Date started December 15, 19 95
Date completed December 16, 19 95

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 138 Feet Depth Cased 138 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From Feet | To Feet |
|---|---|---|
| 10 | 0 | 138 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 12.92 | .188 | 0 | 138 |
| | | | | |
| | | | | |

Perforations:
Type perforation Mill Out
Size perforation 1/8 inch
From 135 feet to 138 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 138 feet

9. WATER LEVEL
Static water level 41.93 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, Nv 89407

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed Wyn Pars
By driller performing actual drilling on site or contractor

Date 2-23-96

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627