WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65169
Permit No.
Basin 101

NOTICE OF INTENT NO. 28216

1. OWNER MIKE CASEY
MAILING ADDRESS 1550 S. ALLEN ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION
5390 VANESSA

2. LOCATION SW 1/4 NE 1/4 Sec. 20 T 19N N/S R 28E E CHURCHILL County
PERMIT NO. _____ Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	15	15
BROWN CLAY		15	18	3
BROWN SAND		18	31	13
BROWN CLAY		31	32	1
BROWN SAND	X	32	41	9
BROWN CLAY		41	43	2
MC SANDS\GRAVEL	X	43	55	12

RECEIVED
96 MAY -8 AM 11:23
STATE ENGINEERS OFFICE

Date started 4/23/96, 19__
Date completed 4/23/96, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		1 hr.

8. WELL CONSTRUCTION

Depth Drilled 55 Feet Depth Cased 55 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3/4	Inches	0	Feet	25	Feet
6 5/8	Inches	25	Feet	55	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+01	55

Perforations:
Type perforation MACHINE SLOT
Size perforation .090
From 48 feet to 53 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 25 FT
Placement Method: [ ] Pumped [X] Poured

Seal Type:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From _____ feet to _____ feet

9. WATER LEVEL

Static water level 11.5 feet below land surface
Artesian flow 30 G.P.M. _____ P.S.I.
Water temperature 62 °F Quality UNTESTED

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Corp.
Contractor

Address P. O. BOX 888
Contractor

FALLON, NV 89407

Nevada contractor's license number issued by the State Contractor's Board 11752

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996

Signed Jesus Marizcurrena
By driller performing actual drilling on-site or contractor

Date 4-23-96