WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65171
Permit No.
Basin 101

NOTICE OF INTENT NO. 28218

1. OWNER MIKE CASEY
MAILING ADDRESS 1550 S ALLEN ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION
5480 VANESSA

2. LOCATION SW 1/4 NE 1/4 Sec. 20 T 19 N/S R 28 E CHURCHILL County
PERMIT NO. _____ Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	18	18
BROWN CLAY		18	20	2
BROWN SAND		20	30	10
BROWN CLAY		30	32	2
BROWN SAND	X	32	41	9

RECEIVED 96 MAY -8 AM 11:23 STATE ENGINEER'S OFFICE

Date started 4/28/96, 19__
Date completed 4/28/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 41 Feet Depth Cased 41 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 3\4	Inches	0	Feet	25	Feet
6 1\4	Inches	25	Feet	41	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5\8	12.9	.188	+01	41

Perforations:
Type perforation MACHINE SLOT
Size perforation .090
From 34 feet to 39 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [ ] Yes [X] No
Depth of Seal 25 FT
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From _____ feet to _____ feet

9. WATER LEVEL
Static water level 11.83 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature 62 °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Drilling Corp. (Contractor)
Address P. O. BOX 888 (Contractor)
FALLON, NV 89407

Nevada contractor's license number issued by the State Contractor's Board 11752

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996

Signed Jesus Maiscurena
By driller performing actual drilling on-site or contractor
Date 4-28-96