WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65177
Permit No.
Basin 101

NOTICE OF INTENT NO. 28496

1. OWNER Mike CASEY
MAILING ADDRESS 1550 S Allen
ADDRESS AT WELL LOCATION 5435 VIANESSIA Dr.

2. LOCATION SW ¼ NE ¼ Sec. 20 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sands		0	15	15
Brown Sands / clay		15	30	15
Brown Sands	✓	30	40	10

Date started 3-20, 1996
Date completed 3-20, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		1

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	30 Feet
6 1/8 Inches	30 Feet	40 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	1/8	+1	40

Perforations:
Type perforation machine cut
Size perforation .080
From 33 feet to 38 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 30
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 8' 6"
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality OK

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco Corp (Contractor)
Address 335 N Broadway (Contractor)
Fallon, NV
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed Jesus Marrancurrin (By driller performing actual drilling on site or contractor)
Date 3-20-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65177
Permit No.
Basin 101

NOTICE OF INTENT NO. 28497

1. OWNER Mike Casey 1550 S Allen ADDRESS AT WELL LOCATION 5405 Vanessa Dr
MAILING ADDRESS

2. LOCATION SW ¼ NE ¼ Sec. 20 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown sand		0	15	15
Brown sands/clay		15	30	15
Brown clay		30	33	3
Brown sands	x	33	41	8

Date started 3-20, 19 96
Date completed 3-20, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10		1

8. WELL CONSTRUCTION
Depth Drilled 41 Feet Depth Cased 41 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	30 Feet
6 1/8 Inches	30 Feet	41 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	1/8	11	41

Perforations:
Type perforation machine cut
Size perforation .080
From 34 feet to 39 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 30
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 8' 3" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality ok

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welsco Corp (Contractor)
Address 335 N Broadway (Contractor)
Fallon, NV
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1996
Signed Jesus Manucuma (By driller performing actual drilling on site or contractor)
Date 3-20-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627