WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65183
Permit No.
Basin 101

NOTICE OF INTENT NO. 30538

1. OWNER GAry Hutchings
MAILING ADDRESS 710 W. Williams Ave.
Fallon, NV. 89406

ADDRESS AT WELL LOCATION
1450 Melanie Dr.
Fallon, NV. 89406

2. LOCATION NE ¼ SE ¼ Sec 20 T 19 N/S R 28 E Churchill County

PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	6	6
Coarse Sand		6	17	11
Brown Clay		17	24	7
Coarse Sand		24	29	5
Brown Clay		29	36	7
Coarse Sand		36	38	2
Brown Clay		38	42	4
Coarse Sand/Gravel		42	49	7
Gray Clay		49	52	3
Green Sand/Gravel		52	69	17
Sandy Gray Clay		69	72	8
Coarse Green SAnd		72	85	8
Sandy Gray Clay		85	96	11
Green Sand		96	104	8
Black Clay Sand		104	114	10
Green Coarse Sand				
Gravel	XX	114	128	14
Gray Clay		128	134	6
Coarse Sand/Gravel	XX	134	139	5
Brown Clay		139	140	1

RECEIVED 96 JAN 19 AM 11:08 STATE ENGINEER'S OFFICE

Date started 1-11, 19 96
Date completed 1-11, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	140

Perforations:
Type perforation Mill-Cut
Size perforation 1/8"
From 137 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100ft.
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 140 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name PARSONS DRILLING, INC. (Contractor)
Address P.O. BOX 1265 (Contractor)
FALLON, NV. 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454
Signed Norman Parsons (By driller performing actual drilling on site or contractor)
Date 1-16-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627