

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30597

1. OWNER Tim Henderson ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 340 Prickley Pear same
Verdi, Nevada 89346
 2. LOCATION SE 1/4 SE 1/4 Sec 7 T. 19N N/S R 18E E Washoe County
 PERMIT NO. 038-045-27 Parcel No. Verdi Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL DEEPENING				
Fill		134	138	4
Dark Gray rock (med hard)		138	153	15
Dark gray rock (soft zone)		153	155	2
Dark gray rock (med hard)		155	168	13
Dark gray rock (soft zone)		168	170	2
Dark gray rock (med hard)		170	182	12
Dark gray rock (hard)		182	191	9
Gray rock w/clay streaks		191	205	14
Gray rock (med hard)		205	221	16
Gray rock (softer)		221	249	28
Gray rock (med hard)		249	251	2
Gray rock/weathered & broken		251	271	20
Gray rock med.		271	280	9
Gray rock (med hard)		280	322	42
Dark gray/black rock				
broken & fracture	X	322	328	6
Gray rock, soft		328	347	19
Soft gray rock/w clay		347	352	5

8. WELL CONSTRUCTION
 Depth Drilled 352 Feet Depth Cascd 338 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
6 1/8 Inches 134 Feet 352 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		.188	0	338

Perforations:
 Type perforation Factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From _____ feet to _____ feet
 From 138 feet to 158 feet
 From 298 feet to 338 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal Deepening Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 142 feet to 338 feet

9. WATER LEVEL
 Static water level 44.5 feet below land surface
 Artesian flow _____ G.P.M. 21 P.S.I.
 Water temperature cold °F Quality clear

Date started 4-10-96, 19_____
 Date completed 4-12-96, 19_____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>21</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number 22549 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
 Signed Mary C. [Signature]
 By driller performing actual drilling on site or contractor
 Date April 16, 1996