WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65194
Permit No.
Basin 091

NOTICE OF INTENT NO. 33224

1. OWNER Washoe County School District
MAILING ADDRESS 425 East Ninth Street
Reno, NV 89520

ADDRESS AT WELL LOCATION 250 Bridge Street
Verdi, NV 89439

2. LOCATION SW ¼ SW ¼ Sec. 8 T. 19 N/S R. 18 EAST WASHOE County
PERMIT NO. 49790 (Issued by Water Resources) 038-060-04 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Set up perforate 8-5/8 casing from 0 to 277. Install 2" trimie pipe to total depth pump approx 15,995.47 lbs. of neat cement to abandon.				
ABANDON T.D. 277				

RECEIVED 96 SEP 19 AM 11:26 STATE ENGINEERS OFFICE

Date started September 6, 19 96
Date completed September 7, 19 96

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 277 Feet Depth Cased 277 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8-5/8	10.5	.156	+2	277

Perforations:
Type perforation Air perforator
Size perforation 2 x 1/2
From 0 feet to 277 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 80 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A.S.A.P. Pump & Well Service Inc. (Contractor)
Address 1800½ Frazer Avenue (Contractor)
Sparks, NV 89431
Nevada contractor's license number issued by the State Contractor's Board 35387-A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1509-T1
Signed Larry Welch (By driller performing actual drilling on site or contractor)
Date 9-16-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627