

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **15618**

1. OWNER Elaine Arnold ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 210 Appian Way 671 Sunset Rd
Henderson NV 89015
 2. LOCATION NE 1/4 SW 1/4 Sec 2 T 22 R 62 E Clark County
 PERMIT NO. MO-2747A 178-02-302-001 Subdivision Name _____
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG MW-5

Material	Water Strata	From	To	Thickness
Fill - 2" AC/base		0	1	
SAVAY Gravel		1	6	
SILTY SAND		6	8.5	
SANDY Gravel		8.5	13	
CALICHE		13	18.5	
SILTY SAND		18.5	20	
CLAYEY SAND	Y	20	22.5	
CALICHE	Y	22.5	24	
CLAYEY SAND	Y	24	26	
CALICHE	Y	26	27.5	
CLAYEY SAND	Y	27.5	30	

8. WELL CONSTRUCTION
 Depth Drilled 30 Feet Depth Cased 30 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 Inches To 30 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>PVC</u>	<u>sch 40</u>	<u>0</u>	<u>30</u>

 Perforations:
 Type perforation slotted screen
 Size perforation .010 inch
 From 15 feet to 30 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 14 _____
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 14 feet to 30 feet

Date started 2/11, 1997
 Date completed 2/11, 1997

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 18.81 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Tim Allen of Terracon Consultants
 Address 4343 S. Polaris Ave
LV 89103
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2017
 Signed Kenneth A. Koberna
 By driller performing actual drilling on site or contractor
 Date 5-29-97