WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65232
Permit No.
Basin 212

NOTICE OF INTENT NO. 15618

1. OWNER Elaine Arnold
MAILING ADDRESS 210 Appian Way, Henderson, NV 89015
ADDRESS AT WELL LOCATION 671 Sunset Rd

2. LOCATION NE ¼ SW ¼ Sec. 2 T. 22 N/S R. 62 E. Clark County
PERMIT NO. MO-2747A (Issued by Water Resources) 178-02-302-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG MW-6

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Fill - Asphalt over base | | 0 | 1.5 | |
| SILTY SAND - w/gravel | | 1.5 | 3.5 | |
| Gravelly SAND - w/silt | | 3.5 | 9 | |
| SILTY SAND - w/gravel | | 9 | 17 | |
| CLAYEY SAND - w/silt | | 17 | 18 | |
| SILTY CLAY | | 18 | 20 | |
| SILTY SAND - w/cntd lenses | Y | 20 | 30 | |

Date started 5/14, 1997
Date completed 5/14, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 31 Feet Depth Cased 30.5 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 8¼ Inches | | 0 Feet | 31 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2 | PVC | sch 40 | 0 | 30.5 |
| | | | | |
| | | | | |

Perforations:
Type perforation slotted screen
Size perforation .010 inch
From 15.5 feet to 30.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 14
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 14 feet to 31 feet

9. WATER LEVEL
Static water level 19.98 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name T. A. c/o Terracon Consultants (Contractor)
Address 4343 S. Polaris Ave (Contractor)
LV, NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M2017
Signed Kenneth A. Kutanni
By driller performing actual drilling on site or contractor
Date 5-29-97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627