WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65248
Permit No.
Basin 162

NOTICE OF INTENT NO. 16288

1. OWNER HAROLD & PATRICIA GARBISCO
MAILING ADDRESS
ADDRESS AT WELL LOCATION 1611 E. SANTOVITO ST.

2. LOCATION SW ¼ SE ¼ Sec. 14 T. 21-S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 44-742-05 (Parcel No.) MESA OESTE UNIT 2 BLK 13 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Surface | | 0 | 4 | 4 |
| Gray clay | | 4 | 8 | 4 |
| Gray clay/caliche | | 8 | 15 | 7 |
| Gray clay | | 15 | 26 | 11 |
| Limestone | | 26 | 34 | 8 |
| Gray clay/caliche | | 34 | 68 | 34 |
| Brown clay/caliche | X | 68 | 91 | 23 |
| Brown clay | | 91 | 107 | 16 |
| Gray clay/caliche | | 107 | 138 | 31 |
| Gray clay | | 138 | 148 | 10 |
| Brown clay/caliche | X | 148 | 160 | 12 |

Date started May 12, 19 97
Date completed May 12, 19 97

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | 4 | ¼ |

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12 Inches | | 0 Feet | 160 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8 | 16.94 | .188 | 0 | 160 |
| | | | | |
| | | | | |

Perforations:
Type perforation Torch Cut
Size perforation ½" width 8" long
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JIM PIKE WELL DRILLING, LLC. (Contractor)
Address P. O. BOX 56 (Contractor)
PAHRUMP, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 17563A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812
Signed (By driller performing actual drilling on site or contractor)
Date May 13, 1997

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627