WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65275
Permit No.
Basin 102

NOTICE OF INTENT NO. 30151

1. OWNER Carl Sandgren
MAILING ADDRESS P.O. Box 692
Fallon, NV 89407

ADDRESS AT WELL LOCATION
415 Hunter Park Way, Fallon, NV 89406

2. LOCATION NE 1/4 NW 1/4 Sec. 30 T 19N N/S R 29 E Churchill County
PERMIT NO. _____ (Issued by Water Resources) | 008-313-17 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	17	17
Brown Sand		17	20	3
Gray Sand		20	40	20
Sandy Clay		40	60	20
Brown & Gray Clay		60	76	16
Gray Sand		76	80	4
Brown Sand	X	80	94	14
Gray Clay		94	96	2

RECEIVED 96 OCT 29 P12:41 STATE ENGINEER

Date started 10/8/96, 19__
Date completed 10/8/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1 hr.

8. WELL CONSTRUCTION
Depth Drilled 96 Feet Depth Cased 96 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	96	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	96

Perforations:
Type perforation Mill CUt
Size perforation 1/8
From 93 feet to 96 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 96 feet

9. WATER LEVEL
Static water level 6 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1454

Signed Norman Parsons
By driller performing actual drilling on-site or contractor

Date 10-24-96