WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 65276
Permit No.
Basin 076

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 19559

1. OWNER Robert Burton
MAILING ADDRESS 1155 Whipple Tree Ln. Fernley, Nev. 89408
ADDRESS AT WELL LOCATION 1335 Woody Lane Fernley, Nev. 89408

2. LOCATION NW ¼ SW ¼ Sec. 22 T. 20 N/S R. 25 E. County
PERMIT NO. (Issued by Water Resources) 021-342-09 (Parcel No.) Nelson (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand-Clay & Mid size Rock		0'	21'	21'
Sandy Clay		21'	32'	11'
Sandy Clay & gravel		32'	60'	28'
Sandy Clay		60'	73'	13'
Small gravel & clay		73'	80'	7'
Gravel		80'	84'	4'
Sandy Clay		84'	98'	14'
Small Gravel & Clay		98	103'	5'
Medium gravel	8'	103'	111	8'
Hard Clay		111'	116'	5'
Small gravel & Clay		116'	120'	4'
Hard Clay		120'	122'	2'

RECEIVED 97 JAN 14 AM 10:59 SPEC. OFFICE

Date started 10-25, 1996
Date completed 12-15, 1996

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3500	30	6'	10 hrs.

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6" inches Total depth 122' feet
..... inches
..... inches
Casing record Steel
Weight per foot 13# Thickness .188

Diameter	From	To
6" inches	0' feet	120' feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement Grout
Depth of seal 100' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Machine Slotted
Size perforation 3/32"
From 102' feet to 122' feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 64' feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 55 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name B & B Drilling (Contractor)
Address PO Box 272 Fernley Nv. 89408 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0014831
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1532
Signed W. R. Biedenguer (By driller performing actual drilling on site or contractor)
Date 12-30-96

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627