WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65277
Permit No.
Basin 083

NOTICE OF INTENT NO. 27968

1. OWNER Kaiser Sierra Micromill
MAILING ADDRESS 6177 Sunol Blvd
Pleasanton, CA 94566
ADDRESS AT WELL LOCATION 1400 Waltham Way
Sparks, NV 89434

2. LOCATION NE ¼ SE ¼ Sec. 32 T 20 N/S R 22 E Storey County
PERMIT NO. 61736 (Issued by Water Resources) 04 09 12 (Parcel No.) None (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
A 600 FT TEST WELL WAS DRILLED PRIOR TO THE PRODUCTION WELL				
WIND BLOWN SAND W V MNR SMALL GRVLS		0	22	22
VOL RUBBLE		22	40	18
RIVER DEBRIS, SAND, GRVL, MINOR BRWN CLAY SEAMS. PROBABLY TRUCKEE FM, ALTERED AND WASHED		40	130	90
FRACTURED, RUBBLE, INTO SOLID RHY		130	580	450
DARK BRWN CLAY PRE-VOL LAKE BOTTOM OR RIVER		580	600	20

Date started 1/26, 1996
Date completed 8/15, 1996

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [X] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
200-400		72

8. WELL CONSTRUCTION
Depth Drilled 600 Feet Depth Cased 600 Feet

HOLE DIAMETER (BIT SIZE)

		From		To
22 Inches		0 Feet		55 Feet
14 3/4 Inches		55 Feet		140 Feet
12 3/4 Inches		140 Feet		600 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16	42	1/4	+1	55
8	22	1/4	+3	600

Perforations:
Type perforation Screen
Size perforation 0.080
From 125 feet to 165 feet
From 260 feet to 320 feet
From 380 feet to 500 feet
From 540 feet to 580 feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 55
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 0 feet to 600 feet

9. WATER LEVEL
Static water level 76 feet below land surface
Artesian flow No G.P.M. P.S.I.
Water temperature COLD °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Drilling, Inc (Contractor)
Address 75 Lewers Crk Rd (Contractor)
Carson City, NV 89704
Nevada contractor's license number issued by the State Contractor's Board 13697A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed Joe Leisch (By driller performing actual drilling on site or contractor)
Date 1/8/97

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627