



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16639

1. OWNER NEVADA BELL ADDRESS AT WELL LOCATION 530 S. Blagg Rd.  
 MAILING ADDRESS 530 S. Blagg Rd. Pahrump, NV 89048

2. LOCATION NE 1/4 SE 1/4 Sec. 16 T. 20S. N/S R. 53 E. Nye County  
 PERMIT NO. 62393 35-353-08 Bolling Green Acres  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Brown Clay		4	18	14
Caliche		18	23	5
Brown Clay		23	33	10
Caliche		33	39	6
Grey Clay	X	39	84	45
Hard Lime		84	88	4
Brown Clay	X	88	151	63
Broken Caliche & Clay		151	174	23
Soft Clay	X	174	188	14
Hard Lime		188	194	6
Soft Clay (Artesian Area)	X	194	197	3
Hard Lime		197	200	3

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
1.2 Inches 0 Feet 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	17 1/2	.188	0	200

Perforations:  
 Type perforation Torch cut  
 Size perforation 1/4" wide, 8" long  
 From 160 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

9. WATER LEVEL  
 Static water level: 33 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started June 2, 1997  
 Date completed June 9, 1997

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	-0-	15 min

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Charles Nyberg Contractor  
 Address 1060 W. Basin Rd Contractor  
Pahrump, NV 89048  
 Nevada contractor's license number issued by the State Contractor's Board: 7484  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 725  
 Signed Charles Nyberg  
 By driller performing actual drilling on site or contractor  
 Date June 9, 1997