



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15531

1. OWNER Claude & Mary Woody ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3330 S. Rodeo 3330 S. Rodeo Pahrump, NV 89048
Pahrump, NV 89048

2. LOCATION SE 1/4 NW 1/4 Sec. 34 T 20S N/S R 53E E Nye County
 PERMIT NO. 40-663-10 Calvada Valley Subdivision Name _____
 Issued by Water Resources Parcel No. _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	6	6
Grey Calache		6	14	8
Light Brown Calache		14	34	20
Light Brown Clay		34	47	13
Brown Calache		47	58	11
Grey Calache	x	58	77	19
Light Brown Clay	x	77	103	26
Tan Calache	x	103	120	17
Light Brown Calache	x	120	133	13
Brown Clay	x	133	140	7

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
12 3/4 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	140

Perforations:
 Type perforation TORCH
 Size perforation .25 x 6
 From 110 feet to 130 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Strickland Construction Co., Inc. Contractor
 Address 2301 Winery Road, Suite 2 Contractor
Pahrump, NV 89048
 Nevada contractor's license number issued by the State Contractor's Board 40277
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2025
 Signed Larry Strickland
 By driller performing actual drilling on-site or contractor
 Date 6-4-97

Date started 6/3/97, 19____
 Date completed 6/3/97, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>	<u>na</u>	<u>.50</u>

