WHITE–DIVISION OF WATER RESOURCES
CANARY–CLIENT'S COPY
PINK–WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65328
Permit No.
Basin 212

NOTICE OF INTENT NO. 17681

1. OWNER Clark County Dept. of Pub. Works
MAILING ADDRESS 6655 W. Sahara Ave. Las Vegas, NV 89102
ADDRESS AT WELL LOCATION Southwest corner of Flamingo Road and Las Vegas Boulevard South

2. LOCATION NE ¼ NE ¼ Sec. 20 T. 21 N/S R. 61 E. Clark County
PERMIT NO. MD-2773 Issued by Water Resources
162-20-501-002 Parcel No.
Subdivision Name

3. WORK PERFORMED: ☒ New Well ☐ Replace ☐ Recondition ☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE T-11: ☐ Domestic ☐ Irrigation ☐ Test ☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE: ☐ Cable ☒ Rotary ☐ RVC ☐ Air ☐ Other

6. LITHOLOGIC LOG T-11

Material	Water Strata	From	To	Thickness
Fill		0'	7'	7'
Caliche		7'	15'	8'
Gravelly Sand		15'	17'	2'
Caliche		17'	19'	2'
Sandy Clay	X	19'	25'	6'
Caliche		25'	27'	2'
Gravelly Clay		27'	35'	8'
Clay		35'	80'	45'

Date started January 17, 19 97
Date completed January 17, 19 97

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 75 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	80' Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	1.9	0.237	0	75

Perforations:
Type perforation: Factory Slot
Size perforation 0.020"
From 30 feet to 75 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0'-5' neat cement, 5'-25' bentonite
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 25 feet to 80 feet

9. WATER LEVEL
Static water level 20.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Wilson
Contractor
Address 731 Pilot Road, Suite H
Contractor
Las Vegas, NV 89119
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589
Signed Donald S. Wilson
By driller performing actual drilling on site or contractor
Date 6-4-97

RECEIVED JUN 9 1997 WATER RESOURCES

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627