


OFFICE USE ONLY
 Log No. 65334
 Permit No. _____
 Basin 212



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17712
3667 S. LAS VEGAS BLVD

1. OWNER ALADDIN HOTEL ADDRESS AT WELL LOCATION 3667 S. LAS VEGAS BLVD LAS VEGAS NV
 MAILING ADDRESS 3667 LAS VEGAS BLVD SO. LAS VEGAS, NV

2. LOCATION SE 1/4 NW 1/4 Sec 21 T 21 N 61 E CLARK County
 PERMIT NO. MO-2776 Issued by Water Resources Parcel No. 1162-21-201-001 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE MW-75
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ASPHALT/FILL		0	4.5	4.5
LEAN CLAY		4.5	9	4.5
CLAYEY SAND		9	18	9
CALICHE		18	19	1
LEAN CLAY		19	20	1
CALICHE		20	23	3
SANDY CLAY		23	24	1
CLAYEY SAND		24	29	5
LEAN CLAY		29	35	6
SANDY CLAY		35	36	1
CALICHE		36	37.5	1.5
SANDY CLAY		37.5	38	0.5
CALICHE		38	39.5	1.5
SANDY CLAY		39.5	40	0.5

8. WELL CONSTRUCTION
 Depth Drilled 40 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)
 From 6 Inches 0 Feet To 40 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.64</u>	<u>0.154</u>	<u>0</u>	<u>35</u>

Perforations:
 Type perforation FACTORY SLOT
 Size perforation 0.020
 From 20 feet to 35 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0-12'/12-15' BELTONE Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 15 feet to 40 feet

9. WATER LEVEL
 Static water level: 19.2 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name DON WILSON (CONVERSE CONS)
 Address 731 PILOT RD Ste H LAS VEGAS, NV 89119
 Nevada contractor's license number 0034757
 issued by the State Contractor's Board
 Nevada driller's license number issued by the M1589
 Division of Water Resources, the on-site driller
 Signed Don Wilson
 By driller performing actual drilling on site or contractor
 Date 6-5-97

Date started JAN 28 1997
 Date completed JAN 28 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			