



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15925

1. OWNER Southern Nevada Water Authority ADDRESS AT WELL LOCATION 220 feet east of the Slogen channel and 75 feet north of Tangiers
 MAILING ADDRESS 1850 E. Flamingo Road Las Vegas, NV 89119
 2. LOCATION SE 1/4 NW 1/4 Sec 10 T 21 N R 62 E Clark County
 PERMIT NO. 161-10-196-001 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE 0-8B
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other Auger

6. LITHOLOGIC LOG 0-8B

Material	Water Strata	From	To	Thickness
<u>Lean clay</u>		<u>0'</u>	<u>33'</u>	<u>33'</u>
<u>Clayey sand</u>		<u>33'</u>	<u>36'</u>	<u>3'</u>
<u>Lean clay</u>		<u>36'</u>	<u>39'</u>	<u>3'</u>

8. WELL CONSTRUCTION
 Depth Drilled 0 Feet Depth Cased 39 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet 39 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.64</u>	<u>0.154</u>	<u>0</u>	<u>39</u>

Perforations:
 Type perforation Feeding Slot
 Size perforation 0.027
 From 19 feet to 39 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0-1 feet neat cement Neat Cement
 Placement Method: Pumped Poured Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 15 feet to 39 feet

9. WATER LEVEL
 Static water level 11.0 feet below land surface
 Artesian flow _____ G.P.M.
 Water temperature _____ °F Quality _____

Date started April 1, 1997
 Date completed April 1, 1997

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Thomas High Contractor
 Address 731 Pilot Road, Suite H Las Vegas, NV 89119 Contractor
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources the on-site driller M-1869
 Signed _____ By driller performing actual drilling on site or contractor
 Date 6-5-97

