WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65348
Permit No.
Basin 105

NOTICE OF INTENT NO. 28487

1. OWNER DECARLO CUSTOM HOMES
MAILING ADDRESS MINDEN, NV
ADDRESS AT WELL LOCATION 2363 JUNIPER FISH SPRINGS

2. LOCATION NE ¼ NE ¼ Sec. 32 T 13 N/S R 21 E DOUGLAS County
PERMIT NO. — (Issued by Water Resources) 23-160-33 (Parcel No.) FISH SPRINGS (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY		0	11	11
CEMENTED GRAVEL		11	20	9
SANDY CLAY/GRAVEL		20	46	26
SAND GRAVEL		46	51	5
SANDY CLAY		51	66	15
SAND/GRAVEL		66	81	15
SANDY CLAY		81	96	15
SAND GRAVEL	✓	96	102	6
SANDY CLAY		102	105	3
SAND/GRAVEL	✓	105	150	45

RECEIVED 97 FEB 2 AM 11:19 STATE ENGINEER'S OFFICE

Date started 12-9, 1996
Date completed 12-12, 1996

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	20	—	1

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	50 Feet
9 7/8 Inches		50 Feet	150 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	+1	150

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3 x 1/8
From 130 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 150 feet

9. WATER LEVEL
Static water level 63 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC. (Contractor)
Address 879 RITTER DR. (Contractor)
GARDNERVILLE, NV 89410
Nevada contractor's license number issued by the State Contractor's Board 27673A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1997
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 12-11-96

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627