

OFFICE USE ONLY
 Log No. 65370
 Permit No. _____
 Basin. 09

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 17885

1. OWNER CHARLES D. KELLY ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 300 Prickley Pear Same
Verdi, Nevada 89439
 2. LOCATION SE 1/4 SE 1/4 Sec. 7 T. 19N N/S R. 18 E Washoe County
 PERMIT NO. 038-045-23 Verdi
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL DEEPENING:				
Static water level at <u>42 feet</u>				
Cased to <u>70 feet</u>				
Yield <u>10 GPM.</u>				
Black volcanic clay with gravels		70	90	20
Cemented gravels with gray clay		90	99	9
Gray clay		99	132	33
Soft zone	X	132	137	5
Dark brown sandy clay		137	142	5
Soft zone	X	142	146	4
Dark brown clays		146	155	9
Soft zone	X	155	161	6
Dark brown clays		161	177	16
Gray sandy clay		177	182	5
Soft zone	X	182	185	3
Dark brown clay		185	194	9
Gray clay		194	203	9

8. WELL CONSTRUCTION
 Depth Drilled 203 Feet Depth Cased 203 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 1/8 Inches To 70 Feet 203 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"OD		.188	0	203

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 119 feet to 199 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Depth of Seal deepening Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 100 feet to 203 feet

9. WATER LEVEL
 Static water level 50 feet below land surface
 Artesian flow _____ G.P.M. 30+ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number 22549
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date August 30, 1996

Date started 8-27-96, 19____
 Date completed 8-28-96, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30+</u>		

RECEIVED
 26 SEP - 6 PM 2:11
 STATE ENGINEERS OFFICE