WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 65388
Permit No.
Basin 170

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER Bob & Susan Russell ADDRESS AT WELL LOCATION Rachel NV
MAILING ADDRESS Star Rt. Alamo NV 89001

2. LOCATION NE ¼ NE ¼ Sec. 35 T. 3 S N/S R. 55 E Lincoln County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☒ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	3	3
Sand & gravel		3	80	77
gravel		80	90	10
Layers of cemented sand & gravel		90	160	70

RECEIVED
AUG 13 1984
Div. of Water Resources
Branch Office — Las Vegas, Nev.

8. WELL CONSTRUCTION
Diameter hole 12" 0-50' 8" 50-160' inches Total depth 160 feet
Casing record
Weight per foot Thickness .188

Diameter	From	To
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Concrete
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 160 feet

Perforations:
Type perforation Torch
Size perforation ¼ to 12"
From 100 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 68 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cold ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Darell H. Free (Contractor)
Address Panaca Nev. (Contractor)
Nevada contractor's license number 30
Nevada contractor's drillers number 4322
Nevada driller's license number 455 (Actual Driller)
Signed Darell H Free (Contractor)
Date Aug 7-84

Date started July 23, 19 84
Date completed Aug 4, 19 84

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 20 Draw down not measurable feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434