WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 65524
Permit No.
Basin 209

in Book

#0973

1. OWNER Alamo Sewer and water ADDRESS

2. LOCATION S/E ¼ S/E ¼ Sec. 5 T. 7 South N/S R. 61 E. Lincoln County
PERMIT NO. Production well #5

3. TYPE OF WORK				4. PROPOSED USE				5. TYPE WELL	
New Well	☐	Recondition	☒	Domestic	☐	Irrigation	☐	Test	☐	Cable ☐	Rotary ☐
Deepen	☐	Other	☐	Municipal	☒	Industrial	☐	Stock	☐	Other ☐	

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
I received engineers Log report. I intended to clean out well with air it had hard bottom and I did not gain any footage the well is only 58' The log report the city of alamo received was unreadable except it said the well was 67' deep				

RECEIVED
APR 18 1983
Div. of Water Resources
Branch Office—Las Vegas, Nev.

Date started 4-6-83, 19
Date completed 4-6-83, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION

Diameter hole inches Total depth 58 feet
Casing record
Weight per foot Thickness

Diameter	From	To
8 inches	0 feet	unknown feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type
Depth of seal feet
Gravel packed: Yes ☐ No ☐
Gravel packed from feet to feet

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level 43' Feet below land surface
Flow G.P.M. estimated 2
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Mike Davis
Address Gen. Del. Hiko Nev 89017
Nevada contractor's license number 10791
Nevada driller's license number 1191
Signed Mike Davis
Date 4-12-83

USE ADDITIONAL SHEETS IF NECESSARY

O-627