

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 65583
 Permit No. 45870
 Basin 16a

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 15474

1. OWNER CENTRAL NEVADA UTILITIES COMPANY ADDRESS AT WELL LOCATION 5980 N BLACK ROCK AVE
 MAILING ADDRESS PAHRUMP, NV 89041
 2. LOCATION NE 1/4 NE 1/4 Sec. 15 T 19S N/S R 53E E NYE County COUNTRY VIEW ESTATES
 PERMIT NO. 45870 Issued by Water Resources Parcel No. 29-071-T2 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|----------------------|--------------|------|-----|------------|
| LOOSE GRAVEL & SAND | | 0 | 10 | 10 |
| PACKED SAND & GRAVEL | | 10 | 200 | 190 |
| LOOSE GRAVEL | | 200 | 220 | 20 |
| SAND & GRAVEL | WB | 220 | 400 | 180 |
| LIMESTONE SOLID | | 400 | 425 | 25 |
| LIMESTONE FRACTURED | WB | 425 | 440 | 15 |
| SOLID LIMESTONE | | 440 | 450 | 10 |
| FRACTURED LIMESTONE | WB | 450 | 470 | 20 |
| LIMESTONE | | 470 | 520 | 50 |
| FRACTURED LIMESTONE | WB | 520 | 560 | 40 |
| LIMESTONE | | 560 | 580 | 20 |
| FRACTURED LIMESTONE | WB | 580 | 640 | 60 |
| LIMESTONE | | 640 | 670 | 30 |
| FRACTURED LIMESTONE | WB | 670 | 690 | 20 |
| LIMESTONE | | 690 | 750 | 60 |
| FRACTURED LIMESTONE | WB | 750 | 760 | 10 |
| LIMESTONE | | 760 | 780 | 20 |
| FRACTURED LIMESTONE | WB | 780 | 800 | 20 |
| LIMESTONE | | 800 | 815 | 15 |

8. WELL CONSTRUCTION
 Depth Drilled 815 Feet Depth Cased 815 Feet
 HOLE DIAMETER (BIT SIZE)
 From 14.75 Inches To 0 Feet
 From 0 Feet To 815 Feet
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 10.75 | 28.04 | .250 | 0 | 815 |

Perforations:
 Type perforation FACTORY SAW CUT
 Size perforation 1/8 X 3
 From 395 feet to 815 feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 150 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 150 feet to 815 feet

9. WATER LEVEL
 Static water level 210 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Co. Contractor
 Address PO BOX 4220 Contractor
PAHRUMP, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1462
 Signed [Signature]
 Date 4-2-97

Date started 2/10/97, 19____
 Date completed 2/21/97, 19____

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|------------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>240</u> | <u>250</u> | <u>4</u> |