WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65600
Permit No.
Basin 212

NOTICE OF INTENT NO. 10779

1. OWNER ITT SHERATON
MAILING ADDRESS 3753 HOWARD HUGHES PKWY #200, LAS VEGAS, NV 89109
ADDRESS AT WELL LOCATION DESERT INN 3145 LAS VEGAS BLVD S. LAS VEGAS, NV

2. LOCATION NW ¼ & NE ¼ Sec. 16 T. 21 N(S)R. 61 E. CLARK County
PERMIT NO. MO-2298 A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAYEY SAND		0	1	1
SILTY SAND		1	2	1
SILTY CLAY		2	9	7
CLAYEY GRAVEL		9	10.5	1.5
CALICHE		10.5	12.5	2
SILTY CLAY		12.5	19	6.5
CALICHE		19	21	2
SILTY CLAY		21	24	3
CALICHE		24	26	2
SILTY CLAY		26	28	2
CALICHE		28	31	3
TD=31				

RECEIVED
JUL 25 1993
Div. of Water Resources
Drillers Office - Las Vegas, NV

Date started 7-1, 1993
Date completed 7-1, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 31 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches		0 Feet	31 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	0.7 lbs	SCH 40	0	30

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 0.020
From 10 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-6 / 4-6 BENT
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 6 feet to 31 feet

9. WATER LEVEL
Static water level 12.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DON WILSON
Contractor
Address 4670 S. POLARIS AV.
Contractor
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589
Signed
By driller performing actual drilling on site or contractor
Date

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627