

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10781

1. OWNER ITT SHERATON ADDRESS AT WELL LOCATION DESERT INN
 MAILING ADDRESS 3753 HOWARD HUGHES PKWY #200, LAS VEGAS, NV 89109 3145 LAS VEGAS BLVD SO. LAS VEGAS, NV
 2. LOCATION N1/2 1/4 E NE 1/4 Sec 16 T 21 N R 61 E CLARK County
 PERMIT NO. 140-2298B Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>FILL</u>		<u>0</u>	<u>5</u>	<u>5</u>
<u>SILTY CLAY</u>		<u>5</u>	<u>10</u>	<u>5</u>
<u>CEMENTED SAND & GRAVEL</u>		<u>10</u>	<u>19.5</u>	<u>9.5</u>
<u>CLAYEY GRAVEL</u>		<u>19.5</u>	<u>22</u>	<u>2.5</u>
<u>CEMENTED SAND & GRAVEL</u>		<u>22</u>	<u>30</u>	<u>8</u>
<u>CLAYEY GRAVEL</u>		<u>30</u>	<u>31</u>	<u>1</u>

TD = 31'

8. WELL CONSTRUCTION
 Depth Drilled 31 Feet Depth Cased 30 Feet
 HOLE DIAMETER (BIT SIZE)
 From 6 Inches To 31 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>0.7</u>	<u>5/16 40</u>	<u>0</u>	<u>30</u>

Perforations:
 Type perforation FACTORY SCOTTED
 Size perforation 0.10201
 From 10 feet to 30 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 0-6.5/3.5-6.5 BENT Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 6.5 feet to 31 feet

RECEIVED
 AUG 06 1993
 Div. of Water Resources
 Branch Office Las Vegas, NV

Date started 7/12, 1993
 Date completed 7/12, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 19.5 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name DON WILSON
 Address 4670 SO. POLARIS AVE LAS VEGAS, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589
 Signed Don Wilson
 By driller performing actual drilling on site or contractor
 Date _____