WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65720
Permit No.
Basin 212

NOTICE OF INTENT NO. 10552

1. OWNER Focus 2000
MAILING ADDRESS 4495 S. Polaris Ave
Las Vegas, NV 89103

ADDRESS AT WELL LOCATION 3853 S. Highland Dr.

2. LOCATION NW ¼ SW ¼ Sec. 17 T 21 S/N R 61 E/W CLARK County
PERMIT NO. MO-2306A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other HSA auger

6. LITHOLOGIC LOG MW-3

Material	Water Strata	From	To	Thickness
Fill SANDY GRAVEL	N	0	2	2
CALICHE	N	2	4	2
SANDY CLAY	N	4	7	3
SILTY CLAY	N	7	10	3
SILTY SAND	N	10	11	1
SANDY CLAY	N	11	13.5	2.5
SANDY CLAY	Y	13.5	25	11.5

RECEIVED
DEC 6 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 11/24/93, 19
Date completed 11/24/93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 25 Feet Depth Cased 24.5 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	25 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	sch 40	0	24.5

Perforations:
Type perforation slotted screen
Size perforation .010-inch
From 10 feet to 24.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 10
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 25 feet to 10 feet

9. WATER LEVEL
Static water level 13.8 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Jim Aten c/o WTI (Contractor)
Address 3611 W. Tompkins Ave (Contractor)
Las Vegas, NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1761
Signed (By driller performing actual drilling on site or contractor)
Date 12/30

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627