WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65752
Permit No.
Basin 057

NOTICE OF INTENT NO. 35022

1. OWNER Jim Edgemon
MAILING ADDRESS HC61-Box 185
Battle Mountain, NV 89820

ADDRESS AT WELL LOCATION
Antelope Valley

2. LOCATION SW 1/4 NW 1/4 Sec. 1 T 24N N/S R 40 E Lander County
PERMIT NO. 19271 2/82.7 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Clay		0	7	7
Sand & gravel		7	10	3
Sandy clay		10	14	4
Sandy clay w/gravel		14	18	4
Clay		18	35	17
Sand & gravel		35	40	5
Clay		40	65	25
Sand & gravel		65	88	23
Clay		88	94	6
Sand & gravel		94	108	14
Clay		108	137	29
Sand & gravel		137	141	4
Silty clay		141	165	24
Sand & gravel		165	168	3
Soft clay		168	177	9
Sand & gravel		177	180	3
Brown clay		180	188	8
Sand & gravel		188	191	3
Clay		191	196	5
Sand & gravel		196	232	36
Soft clay		232	236	4
Sand & gravel		236	241	5
Soft clay		241	243	2
Sand & gravel		243	262	19
Soft clay		262	276	14
Sand & gravel		276	294	18
Soft clay		294	320	26

Date started 3/9/97, 19__
Date completed 3/10/97, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Did	Not TEST	Pump

8. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
24 Inches		0 Feet	320 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		.250	+2	140

Perforations:
Type perforation Single row mill slot
Size perforation 1/8 X 2 1/2
From 140 feet to 200 mill slot feet
From 200 feet to 220 wire wrap screen
From 220 feet to 320 mill slot feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 320 feet

9. WATER LEVEL
Static water level 105 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 W. Winnemucca Blvd (Contractor)
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1572

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 3-18-97