

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 65753
 Permit No. 62193
 Basin 065
 NOTICE OF INVENT NO. 35851

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **RB Farms** ADDRESS AT WELL LOCATION **RB Farms**
 MAILING ADDRESS **874 E. Woodward** **Golconda, NV 89414**
 Manteca, CA 95337

2. LOCATION **NE** 1/4 **SW** 1/4 Sec. **3** T **33N** N/S R **40** E **Humboldt** County
 PERMIT NO. **62193** Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	10	10
Small gravel		10	34	24
Sandy brown clay		34	39	5
Course sand w/clay		39	98	59
Sand & gravel		98	105	7
Course sand w/clay		105	210	105
Sand & gravel		210	230	20
Sandy clay w/sand layers		230	270	40
Sand & gravel		270	303	33
Clay w/sand layers		303	330	27
Sand & gravel w/clay layers		330	385	55
Brown clay		385	391	6
Gravel w/sand		391	428	37
Gravel w/clay		428	462	34
Large gravel w/small cobbles		462	494	32
Course sand w/small gravel		494	514	20
Brown clay		514	533	19
Sand & gravel w/cobbles		533	570	37

RECEIVED
 MAR 19 AM 11:26
 STATE ENGINEERS OFFICE

N 40.76284
 W 17.46384 NAD27

8. WELL CONSTRUCTION
 Depth Drilled **570** Feet Depth Cased **570** Feet

HOLE DIAMETER (BIT SIZE)
 From **26** Inches To **0** Feet **570** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		.250	+2	570

Perforations:
 Type perforation **Double row mill slot**
 Size perforation **1/8 X 3**
 From **170** feet to **570** feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal **50** Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From **50** feet to **570** feet

Date started **2/13/97**, 19
 Date completed **2/15/97**, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Bailer Draw Down (Feet Below Static)	Pump Time (Hours)	Air Lift
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	2400	150	8	

9. WATER LEVEL
 Static water level **87.3** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **cool** °F Quality **good**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Humboldt Drilling & Pump Co., Inc.** Contractor
 Address **4675 W. Winnemucca Blvd** Contractor
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board **015234**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1713**
 Signed *Jerry A. Tomp*
 By driller performing actual drilling on-site or contractor
 Date **3-18-97**