WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65781
Permit No.
Basin 53

NOTICE OF [redacted]NT NO 35294

1. OWNER RON BARNES
MAILING ADDRESS PO BOX 990
EUREKA, NEVADA

ADDRESS AT WELL LOCATION
BLOCK H LOT 3

2. LOCATION NE ¼ NE ¼ Sec. 17 T. 20 N/S R. 53 E. EUREKA County
PERMIT NO. Issued by Water Resources | 007-391-03 Parcel No. | DEVILS GATE Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	10	10
GRAVEL		10	90	80
GRAVEL, SAND		90	100	10
CLAY, GRAVEL, SAND		100	120	20
GRAVEL, CLAY, SAND	X	120	160	40
CLAY, GRAVEL		160	170	10
CLAY, SAND, GRAVEL		170	200	30

Date started 3-14, 1997
Date completed 3-17, 1997

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10 5/8	0	200

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	200

Perforations:
Type perforation MILL SLOT
Size perforation FACTORY
From 175 feet to 195 [redacted] feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 FT.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 88 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AAA DRILLING AND PUMP (Contractor)
Address 3359 LAST CHANCE RD (Contractor)
ELKO, NEVADA 89801
Nevada contractor's license number issued by the State Contractor's Board 0038169
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2053
Signed (By driller performing actual drilling on site or contractor)
Date 3-18-97

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627