WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

**PRINT OR TYPE ONLY**
**DO NOT WRITE ON BACK**

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65785
Permit No.
Basin 59

NOTICE OF INTENT NO. 28366

1. OWNER Mark Gunter
MAILING ADDRESS 118 17th Street
Battle Mountain, NV 89820

ADDRESS AT WELL LOCATION
3510 John Adams, Battle Mtn. NV 89820

2. LOCATION NW 1/4 SW 1/4 Sec. 32 T 32N N/S R 46 E Lander County
PERMIT NO. _____ Issued by Water Resources | Parcel No. | Subdivision Name

**3. WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

**4. PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

**5. WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

**6. LITHOLOGIC LOG**

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay | | 0 | 9 | 9 |
| Sand & Gravel | | 9 | 18 | 9 |
| Clay | | 18 | 61 | 43 |
| Sand & gravel | | 61 | 85 | 24 |

Date started 12/20/96, 19__
Date completed 12/21/96, 19__

**7. WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 35 | | 2 |

**8. WELL CONSTRUCTION**
Depth Drilled 85 Feet Depth Cased 80 Feet

**HOLE DIAMETER (BIT SIZE)**

| | | From | | To | |
|---|---|---|---|---|---|
| 10 | Inches | 0 | Feet | 85 | Feet |
| | Inches | | Feet | | Feet |
| | Inches | | Feet | | Feet |

**CASING SCHEDULE**

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .188 | +1 | 80 |

**Perforations:**
Type perforation Single row mill slot
Size perforation 1/8 X 3
From 60 feet to 80 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 85 feet

**9. WATER LEVEL**
Static water level 15 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cool °F Quality good

**10. DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.
Contractor
Address 4675 West Winnemucca Blvd.
Contractor
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562

Signed [signature]
By driller performing actual drilling on-site or contractor

Date 12-31-96