WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65788
Permit No.
Basin 059

NOTICE OF INTENT NO. 35834

1. OWNER Frank Sullivan
MAILING ADDRESS PO Box 939
Battle Mountain, NV 89820

ADDRESS AT WELL LOCATION
2400 East, Battle Mtn. NV 89820

2. LOCATION SW 1/4 NW 1/4 Sec. 11 T 31N N/S R 45 E Lander County
PERMIT NO. _____ Issued by Water Resources | 011-420-16 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	14	14
Sand & gravel		14	19	5
Clay		19	71	52
Clay w/sand & gravel layers		71	105	34

Date started 12/19/96, 19__
Date completed 12/19/96, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		2 1/2

8. WELL CONSTRUCTION
Depth Drilled 105 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	105	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	100

Perforations:
Type perforation Single row mill slot
Size perforation 1/8 X 3
From 80 feet to 100 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 105 feet

9. WATER LEVEL
Static water level 12 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature good °F Quality cool

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc.
Contractor
Address 4675 West Winnemucca Blvd.
Contractor
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562

Signed _____
By driller performing actual drilling on-site or contractor

Date 12-31-96