WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65792
Permit No.
Basin 259

NOTICE OF INTENT NO. 35833

1. OWNER Brentlee Homes/Gary Jensen
MAILING ADDRESS PO Box 219
Battle Mountain, NV 89820

ADDRESS AT WELL LOCATION
~~1615 Jensen Court~~ 1615 3200 E.
Battle Mountain, NV 89820

2. LOCATION ____ 1/4 SW 1/4 Sec. 6 T 31N N/S R 46 E Lander County
PERMIT NO. ____ Issued by Water Resources | 11-370-13 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other ____

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other ____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	17	17
Sand & gravel		17	23	6
Clay		23	58	35
Clay w/sand & gravel layers		58	85	27

Date started 1/10/97, 19__
Date completed 1/12/97, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
8		2.5

8. WELL CONSTRUCTION
Depth Drilled 85 Feet Depth Cased 83 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	85 Feet
____ Inches		____ Feet	____ Feet
____ Inches		____ Feet	____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	83

Perforations:
Type perforation Single row mill slot
Size perforation 1/8 X 3
From 63 feet to 83 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 83 feet

9. WATER LEVEL
Static water level 16 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 West Winnemucca Blvd. (Contractor)
Winnemucca, NV 89445

Nevada contractor's license number issued by the State Contractor's Board 015234

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562

Signed [signature] By driller performing actual drilling on-site or contractor
Date 1-22-97