WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 65795
Permit No.
Basin

# WELL DRILLERS REPORT

Please complete this form in its entirety

1 in 30°

1. OWNER Panaca Farmstead ADDRESS Panaca Nev. 89042

2. LOCATION SE ¼ SW ¼ Sec. 5 T. 2S N/S R. 68 E. Lincoln County
PERMIT NO.

| 3. TYPE OF WORK | 4. PROPOSED USE | 5. TYPE WELL |
|---|---|---|
| New Well ☐ Recondition ☒ | Domestic ☒ Irrigation ☐ Test ☐ | Cable ☒ Rotary ☐ |
| Deepen ☐ Other ☐ | Municipal ☐ Industrial ☐ Stock ☐ | Other ☐ |

## 6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| This Well was pumping sand and clay. | | | | |
| It was decided after having trouble with sand in the replacement Well, that we would reline the original which was 12" We installed a 172' - 10" x ¼' Wall. | | | | |

RECEIVED
APR 13 1983
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started Mar. 21, 19 83
Date completed Mar. 30, 19 83

## 7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | 250 | 40 | 40 |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

## 8. WELL CONSTRUCTION

Diameter hole 12" inches Total depth 172 feet
Casing record 172 x 10
Weight per foot ..... Thickness ¼"

| Diameter | From | To |
|---|---|---|
| ..... inches | ..... feet | ..... feet |
| ..... inches | ..... feet | ..... feet |
| ..... inches | ..... feet | ..... feet |
| ..... inches | ..... feet | ..... feet |
| ..... inches | ..... feet | ..... feet |
| ..... inches Original | ..... feet | ..... feet |

Surface seal: Yes ☒ No ☐ Type
Depth of seal ..... feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 0 feet to 172 feet

Perforations:
Type perforation torch
Size perforation
From 110 feet to 172 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

## 9. WATER LEVEL

Static water level 15 Feet below land surface
Flow ..... G.P.M.
Water temperature Warm °F. Quality good

## 10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Darell H. Free
Address Box 122 Panaca, Nev.
Nevada contractor's license number 3422
Nevada driller's license number 30
Signed Darell H. Free
Date april 9, 83

USE ADDITIONAL SHEETS IF NECESSARY

O-627