WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65799
Permit No.
Basin 129

NOTICE OF INTENT NO. 31238

1. OWNER Coyote Creek RANCH
MAILING ADDRESS SR57
Imlay, NV 89418

ADDRESS AT WELL LOCATION SAME

2. LOCATION SE 1/4 SE 1/4 Sec. 5 T 30N N/S R 35 E Pershing County
PERMIT NO. 21318 (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Sand & gravel		5	7	2
Sandy clay & some gravel		7	25	18
Gravel		25	72	47
Gravel & Cobbles		72	78	6
Gravel w/medium sand		78	122	44
Clay		122	123	1
Gravel/cobbles w/clay		123	147	24
Clay		147	150	3
Sandy clay		150	160	10
Sand & gravel		160	170	10
Sand & gravel w/cobbles		170	190	20
Brown Clay		190	193	3
Brown clay w/gravel		193	205	12
Sand & gravel w/cobbles		205	250	45
Sand & gravel w/hard lenses		250	263	13
Sand & gravel		263	282	19
Sand & gravel w/cobbles		282	387	105

Date started 1/8/97, 19__
Date completed 1/10/97, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
3000		9

Pumping level 130' below ground level

8. WELL CONSTRUCTION
Depth Drilled 387 Feet Depth Cased 380 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
24 Inches		0 Feet	387 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16			+1	120

Perforations:
Type perforation Double row mill slot
Size perforation 1/8 X 3
From 120 feet to 380 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 387 feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address 4675 West Winnemucca Blvd. (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713
Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 1-22-97