WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 65801
Permit No.
Basin 07

NOTICE OF INTENT NO. 35452

1. OWNER FLORIDA CANYON MINES, INC.
MAILING ADDRESS P.O. Box 330
IMLAY, NV 89412

ADDRESS AT WELL LOCATION
FLORIDA CANYON MINE

2. LOCATION NW 1/4 NW 1/4 Sec. 11 T 31N N/S R 33E E PERSHING County
PERMIT NO. M/O 1112 (Issued by Water Resources) | WELL A (Parcel No.) | TRACT OF LAND (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other _____

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

6. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BOULDERS, SAND & GRAVEL	390	0	600	600
BOULDERS, SAND & GRAVEL	570	0	600	600

Date started 12/29/96, 19__
Date completed 12/30/96, 19__

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5		6

8. WELL CONSTRUCTION
Depth Drilled 620 Feet Depth Cased 600 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9.5 Inches		0 Feet	600 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.5	PVC	SCH 80	+2	600

Perforations:
Type perforation SCREEN
Size perforation .020
From 200 feet to 600 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 600 feet

9. WATER LEVEL
Static water level 309 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Hackworth Drilling, Inc. (Contractor)
Address P.O. Box 850 (Contractor)
Elko, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689

Signed [signature] (By driller performing actual drilling on-site or contractor)
Date 1-6-97