



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **13752**

1. OWNER TERRIDE HERBERT ARCO c/o Broadbent Assoc. ADDRESS AT WELL LOCATION 4310 W. FARMINGO, LAS VEGAS  
 MAILING ADDRESS 833 NEVADA HWY BOULDER CITY

2. LOCATION SE 1/4 SW 1/4 Sec. 18 T. 21 N. R. 60 E. CLARK County

PERMIT NO. MO-2495 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE MW-1  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Asphalt		0	1'	1'
Silty CLAY		1'	3'	2'
Cemented gravel		3'	10'	3'
Caliche		10'	7'	1'
Silty CLAY		7'	15'	8'
Cemented Gravel		15'	31'	16'
Silty CLAY		31'	40'	9'

8. WELL CONSTRUCTION  
 Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)  
 From 8 Inches To 40 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.04</u>	<u>0.154</u>	<u>0</u>	<u>40</u>

Perforations:  
 Type perforation slotted  
 Size perforation .02  
 From 10 feet to 40 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 60'

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 8 feet to 40 feet

**RECEIVED**  
 NOV 01 1994  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 9-28 1994  
 Date completed 9-28 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Tom High Contractor  
 Address 4100 S. POLARIS LAS VEGAS, NV 89103 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869  
 Signed Tom High  
 By driller performing actual drilling on site or contractor  
 Date 10-31-94