

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 9639

1. OWNER Clark County School Dist. ADDRESS AT WELL LOCATION R.C. WHITE TRAVIS COR.
 MAILING ADDRESS 1700 Galleria, Bldg. C Henderson, NV 89014 4499 S. Arville St. Las Vegas NV
 2. LOCATION SE 1/4 NW 1/4 Sec. 19 T. 21 N. R. 61 E. CLARK County
 PERMIT NO. MO-2147 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG MW-8

Material	Water Strata	From	To	Thickness
Asphalt		0	3"	3"
BROWN SILTY SAND		3"	4'	3'9"
CLAYEY SAND		4'	14'	10'
GRAVELLY SAND		14'	17'	3'
SILTY SAND		17'	22'	5'
CLAYEY SAND	<input checked="" type="checkbox"/>	22'	26'	4'
SANDY CLAY		26'	32'	6'
CALICHE		32'	34E	2.5'
SANDY CLAY		34E	41E	6.5'
SILTY CLAY		41E	45E	4'
	FD		45E	

8. WELL CONSTRUCTION
 Depth Drilled 45 Feet Depth Cased 45 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 45 Feet
 From 0 Feet To 45 Feet
 From 0 Feet To 45 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4-INCH</u>		<u>Sch. 40</u>	<u>0</u>	<u>45</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 0.020 INCH
 From 15 feet to 45 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 11 (2' BENTONITE) Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 13 feet to 45 feet

RECEIVED
 OCT 19 1992
 Div. of Water Resources
 Branch Office - Las Vegas, NV

9. WATER LEVEL
 Static water level 24.0 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Don Wilson Contractor
 Address 4670 S. Palavis Ave Las Vegas, NV Contractor
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589
 Signed Ronald J. Wilson
 By driller performing actual drilling on site or contractor
 Date 10-2-92

Date started 9-8 1992
 Date completed 9-8 1992

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)